

# City of Anderson-Wooded Acres System

## 2016 Consumer Confidence Report

June 20, 2017

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2016 and may include earlier monitoring data.*

**Este informe contiene información muy importante sobre su agua beber.  
Tradúzcalo ó hable con alguien que lo entienda bien.**

Type of water source(s) in use: Subterranean Ground Water

Name & location of source(s): Greater Anderson Area Aquifer

Drinking Water Source Assessment information:

(Tucker Oaks-#6, & Rhyne-#8)

The California Department of Health Services conducted a source water assessment on our well sources in August 2002. Our sources are considered most vulnerable to the following activities not associated with any detected contaminants: 1) golf courses, and 2) known contaminant plumes. Our sources are considered most vulnerable to the following activities associated with chromium and nitrate detected in the water supply: 1) water supply wells, 2) agricultural drainage, 3) fertilizer, pesticide/herbicide application, 4) grazing, 5) high & low density septic systems, and 6) sewer collection systems. A copy of the complete assessment may be viewed by calling the District office at 378-6636.

Time and place of regularly scheduled board meetings for public participation:  
Regularly Scheduled City Council Meetings at 1887 Howard St., Anderson, CA

For more information, contact City of Anderson Public Works Phone: (530) 378-6636

### TERMS USED IN THIS REPORT:

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Primary Drinking Water Standards (PDWS):** MCLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Variations and Exemptions:** Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

|  |  |
|--|--|
| contaminants.  | <b>ppt:</b> parts per trillion or nanograms per liter (ng/L)   |
| <b>ND:</b> not detectable at testing limit                   | <b>pCi/L:</b> picocuries per liter (a measure of radiation)    |
| <b>ppm:</b> parts per million or milligrams per liter (mg/L) | <b>ppq:</b> parts per quadrillion or picogram per liter (pg/L) |
| <b>ppb:</b> parts per billion or micrograms per liter (ug/L) |  |

**The sources of drinking water** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- *Radioactive contaminants*, which can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, USEPA and the state Department of Health Services (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

**Tables 1, 2, 3, 4, 5 and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, are more than one year old.

**TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA**

| Microbiological Contaminants     | Highest No. of detections | No. of months in violation | MCL  | MCLG | Typical Source of Bacteria           |
|----------------------------------|---------------------------|----------------------------|--|------|--------------------------------------|
| Total Coliform Bacteria          | 0                         | 0                          | More than 1 sample in a month with a detection   | 0    | Naturally present in the environment |
| Fecal Coliform or <i>E. coli</i> | 0                         | 0                          | A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i> | 0    | Human and animal fecal waste         |

OUR WATER SYSTEM SAMPLED 0 TOTAL COLIFORM BACTERIA SAMPLE. NO ADDITIONAL REPEAT SAMPLING NEEDED THERE WERE NO CONTAMINATES IN THE WATER SYSTEM. THIS SYSTEM MEETS ALL DRINKING WATER HEALTH STANDARDS

**TABLE 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER**

| Lead and Copper | No. of samples collected | 90 <sup>th</sup> percentile level detected | No. Sites exceeding AL | AL   | MCLG | Typical Source of Contaminant  |
|-----------------|--------------------------|--|------------------------|------|------|--|
| Lead (ppb)      | 5                        | ND   | 0                      | 15   | 0.2  | Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits. |
| Copper (ppm)    | 5                        | 0.412                                      | 0                      | 1.30 | 0.3  | Internal corrosion of household water plumbing systems; erosion of natural deposits; leaching from wood preservatives.         |

**TABLE 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS**

| Chemical or Constituent | Sample Date | Level Detected | Range of Detections | MCL  | PHG (MCLG) | Typical Source of Contaminant               |
|-------------------------|-------------|----------------|---------------------|------|------------|---|
| Sodium (ppm)            | 2012        | 12.6           | 11.8-12.6           | none | none       | Generally found in ground and surface water |
| Hardness (ppm)          | 2012        | 106            | 96-106              | none | none       | Generally found in ground and surface water |

**TABLE 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

| Chemical or Constituent             | Sample Date | Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Source of Contaminant   |
|-------------------------------------|-------------|----------------|---------------------|-----|------------|---|
| Chromium (ppm)                      | 2002        | 2              | 1-2                 | 50  | 100        | Discharge from steel and pulp mills and chrome plating; erosion of natural deposits.  |
| Fluoride (ppm)                      | 2011        | 0.1            | 0.1                 | 2   | 1          | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.  |
| Hexavalent Chromium (ppb)           | 2016        | ND             | ND                  | 10  | .02        | Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits |
| Nitrate (ppm)                       | 2016        | 1.33           | 1.11-1.33           | 10  | 10         | Run-off and leaching from fertilizer Use; leaching from septic tanks & Sewage, erosion of natural deposits.   |
| Nitrite (ppb)                       | 2014        | ND             | ND                  | 1   | 1          | Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits.  |
| Perchlorate (ppb)                   | 2016        | ND             | ND                  | 6   | 6          | Result of environmental contamination from historic aerospace or other industrial operations that used or use, store, or dispose of perchlorate and its salts.                              |
| TTHMs (Total Trihalomethanes) (ppb) | 2014        | ND             | ND                  | 80  | N/A        | By-product of drinking water disinfection.  |
| Haloacetic Acids (ppb)              | 2015        | ND             | ND                  | 60  | N/A        | By-product of drinking water disinfection.  |

|                                  |      |      |             |     |      |  |
|----------------------------------|------|------|-------------|-----|------|--|
| Gross Alpha (pCi/l)              | 2015 | ND   | ND          | 15  | (0)  | Erosion of natural deposits.   |
| Radium 228 (pCi/L)               | 2015 | 0.71 | 0.49 - 0.71 | 5   | 0.19 | Erosion of natural deposits  |
| Benzene (ppb)                    | 2014 | ND   | ND          | 1   | 0.15 | Discharge from plastics, dyes and nylon factories; leaching from gas storage tanks and landfills                                   |
| Carbon tetrachloride (ppt)       | 2014 | ND   | ND          | 500 | 100  | Discharge from chemical plants and other industrial activities   |
| 1,2-Dichlorobenzene (ppb)        | 2014 | ND   | ND          | 600 | 600  | Discharge from industrial chemical factories   |
| 1,4-Dichlorobenzene (ppb)        | 2014 | ND   | ND          | 5   | 6    | Discharge from industrial chemical factories   |
| 1,1-Dichloroethane (ppb)         | 2014 | ND   | ND          | 5   | 3    | Extraction and degreasing solvent; used in the manufacture of pharmaceuticals, stone, clay, and glass products; fumigant           |
| 1,2-Dichloroethane (ppt)         | 2014 | ND   | ND          | 500 | 400  | Discharge from industrial chemical factories   |
| 1,1-Dichloroethylene (ppb)       | 2014 | ND   | ND          | 6   | 10   | Discharge from industrial chemical factories   |
| cis-1,2-Dichloroethylene (ppb)   | 2014 | ND   | ND          | 6   | 100  | Discharge from industrial chemical factories; major biodegradation byproduct of TCE and PCE groundwater contamination              |
| trans-1,2-Dichloroethylene (ppb) | 2014 | ND   | ND          | 10  | 60   | Discharge from industrial chemical factories; minor biodegradation byproduct of TCE and PCE groundwater contamination              |
| Dichloromethane (ppb)            | 2014 | ND   | ND          | 5   | 4    | Discharge from pharmaceutical and chemical factories; insecticide  |
| 1,2-Dichloropropane (ppb)        | 2014 | ND   | ND          | 5   | 0.5  | Discharge from industrial chemical factories; primary component of some fumigants  |
| 1,3-Dichloropropene (ppt)        | 2014 | ND   | ND          | 500 | 200  | Runoff/leaching from nematocide used on croplands  |
| Ethylbenzene (ppb)               | 2014 | ND   | ND          | 300 | 300  | Discharge from petroleum refineries; industrial chemical factories   |
| Methyl-tert-butyl ether (ppb)    | 2014 | ND   | ND          | 13  | 13   | Leaking underground storage tanks; discharges from petroleum and chemical factories  |
| Monochlorobenzene (ppb)          | 2014 | ND   | ND          | 70  | 200  | Discharge from industrial and agricultural chemical factories and drycleaning facilities   |
| Styrene (ppb)                    | 2014 | ND   | ND          | 100 | 0.5  | Discharge from rubber and plastic factories; leaching from landfills   |
| 1,1,2,2-Tetrachloroethane (ppb)  | 2014 | ND   | ND          | 1   | 0.1  | Discharge from industrial and agricultural chemical factories; solvent used in production of TCE, pesticides, varnish and lacquers |
| Tetrachloroethylene (PCE) (ppb)  | 2014 | ND   | ND          | 5   | 0.06 | Discharge from factories, dry cleaners, and auto shops (metal degreaser)   |
| 1,2,4-Trichlorobenzene (ppb)     | 2014 | ND   | ND          | 5   | 5    | Discharge from textile-finishing factories   |

|                               |      |    |    |       |      |  |
|-------------------------------|------|----|----|-------|------|--|
| 1,1,1-Trichloroethane (ppb)   | 2014 | ND | ND | 200   | 1000 | Discharge from metal degreasing sites and other factories; manufacture of food wrappings                                       |
| 1,1,2-Trichloroethane (ppb)   | 2014 | ND | ND | 5     | 0.3  | Discharge from industrial chemical factories   |
| Trichloroethylene (TCE) (ppb) | 2014 | ND | ND | 5     | 1.7  | Discharge from metal degreasing sites and other factories  |
| Toluene (ppb)                 | 2014 | ND | ND | 150   | 150  | Discharge from petroleum and chemical factories; underground gas tank leaks  |
| Trichlorofluoromethane (ppb)  | 2014 | ND | ND | 150   | 700  | Discharge from industrial factories; degreasing solvent; propellant and refrigerant  |
| Vinyl chloride (ppt)          | 2014 | ND | ND | 500   | 50   | Leaching from PVC piping; discharge from plastics factories; biodegradation byproduct of TCE and PCE groundwater contamination |
| Xylenes (ppm)                 | 2014 | ND | ND | 1.750 | 1.8  | Discharge from petroleum and chemical factories; fuel solvent  |

**TABLE 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

| Chemical or Constituent | Sample Date | Level Detected | Range of Detections | MCL | PHG (MCLG) | Typical Source of Contaminant                              |
|-------------------------|-------------|----------------|---------------------|-----|------------|--|
| Iron (ppb)              | 2011        | ND             | ND                  | 300 | N/A        | Leaching from natural deposits; industrial wastes.         |
| Manganese (ppb)         | 2011        | ND             | ND                  | 50  | N/A        | Leaching from natural deposits.                            |
| Chloride (ppm)          | 2011        | 10.5           | 3.40-10.5           | 500 | N/A        | Runoff/leaching from natural deposits; seawater influence. |
| Sulfate (ppm)           | 2011        | 7.0            | 6.80-7.00           | 500 | N/A        | Runoff/leaching from natural deposits; industrial wastes.  |

**TABLE 6 - DETECTION OF UNREGULATED CONTAMINANTS**

| Chemical or Constituent | Sample Date | Level Detected | Action Level (ppb) | Typical Source of Contaminant   |
|-------------------------|-------------|----------------|--------------------|---------------------------------|
| Vanadium (ppb)          | 2003        | 4              | 50                 | Leaching from natural deposits. |

### Additional General Information On Drinking Water

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate

means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

**Lead-Specific Language for Community Water Systems:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Anderson is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.