

City of Anderson-Main System

2008 Consumer Confidence Report

October 22, 2009

*We test the drinking water quality for many constituents as required by State and Federal Regulations.
This report shows the results of our monitoring through December 31, 2007.*

**Este informe contiene información muy importante sobre su agua beber.
Tradúzcalo ó hable con alguien que lo entienda bien.**

Type of water source(s) in use: Subterranean Ground Water

Name & location of source(s): Greater Anderson Area Aquifer

Drinking Water Source Assessment information:

(Diamond-#3A, Stingy-#4, Volonte-#7, Balls Ferry-#9, Hwy 273-#10, & North St-#14)

The California Department of Health Services conducted a source water assessment on our well sources in August 2002. Our sources are considered most vulnerable to the following activities not associated with any detected contaminants: 1) parks, 2) high density housing, 3) parking lots/malls, 4) automobile body and repair shops, 5) active and historic gas stations, 6) road right-of-ways, freeways/state highways, and railroads along transportation corridors, 7) photo processing/printing, 8) confirmed leaking underground storage tanks, 9) known contaminant plumes, and 10) funeral services/graveyards. Our sources are considered most vulnerable to the following activities associated with chromium, fluoride, and nitrate detected in the water supply: 1) water supply, monitoring and agricultural/irrigation wells, 2) agricultural drainage, 3) grazing, 4) low density septic systems, and 5) sewer collection systems. A copy of the complete assessment may be viewed by calling the District office at 378-6636.

Time and place of regularly scheduled board meetings for public participation:
Regularly Scheduled City Council Meetings at 1887 Howard St., Anderson, CA

For more information, contact City of Anderson Public Works Phone: (530) 378-6636

TERMS USED IN THIS REPORT:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Primary Drinking Water Standards (PDWS): MCLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Variations and Exemptions: Department permission

ppb: parts per billion or micrograms per liter (ug/L)	to exceed an MCL or not comply with a treatment technique under certain conditions.
ppt: parts per trillion or nanograms per liter (ng/L)	
pCi/L: picocuries per liter (a measure of radiation)	

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- *Radioactive contaminants*, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, USEPA and the state Department of Health Services (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

Tables 1, 2, 3, 4, and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants	Highest No. of detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	0	0	More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i>	0	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>	0	Human and animal fecal waste

MONITORING REQUIREMENTS FOR CITY OF ANDERSON'S MAIN ZONE

Sampling found there were NO contaminants in the water system. This system meets all drinking water health Standards.

TABLE 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper	No. of samples collected	90 th percentile level detected	No. Sites exceeding AL	AL (ppb)	MCLG	Typical Source of Contaminant
Lead (ppb)	20	ND	0	0.015	2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits.
Copper (ppm)	20	0.341	0	1.3	0.17	Internal corrosion of household water plumbing systems; erosion of natural deposits; leaching from wood preservatives.

TABLE 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	2002-04	14	10-14	none	none	Generally found in ground and surface water
Hardness (ppm)	2002-04	91	56-91	none	none	Generally found in ground and surface water

TABLE 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Chromium (ppm)	2008	0	1-2.8	50	100	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits.
Fluoride (ppm)	2002-04	0.17	ND-0.17	2	1	Naturally occurring
Nitrate (ppm)	2008	2.1	3.20-8.30	45	45	Run-off and leaching from fertilizer Use; leaching from septic tanks & Sewage, erosion of natural deposits.

TABLE 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Chloride (ppm)	2002-04	7.63	3.08-7.63	500	N/A	Runoff/leaching from natural deposits; seawater influence.
Sulfate (ppm)	2002-04	7.90	3.19-7.90	500	N/A	Runoff/leaching from natural deposits; industrial wastes.

TABLE 6 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent	Sample Date	Level Detected	Action Level (ppb)	Typical Source of Contaminant
Vanadium (ppb)	2003	8	50	Leaching from natural deposits.

Additional General Information On Drinking Water

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).